



Couts Heating and Cooling, Inc

Established 1978

Industrial • Commercial • Air Conditioning
Mechanical Piping • Energy Management • Service

Request For Information

Urgent

Expedite

Normal

Job Name: Palo Verde College
2017-3 Classroom Lab. Boiler Replmt

Reference: 00 72 13 GC Scope of work
RFI # 1

Date: 7/24/17

The Scope of work document item 5 indicates (Provide and install new flue vent), the existing vent is double walled stainless steel and meets the requirement for a condensing boiler. Does this vent need to be replaced.?

Possible Cost Impact

Possible Time Impact

Suggested solution: We believe that the existing Boiler flue can be re-used

IF ALL PROPER REGULATIONS ARE MET IN REGARDS TO CONNECTION OF EXISTING FLUE TO NEW BOILER WITHOUT TOTAL REPLACEMENT OF OLD FLUE VENT, THIS DECISION CAN BE LEFT UP TO THE CONTRACTOR. HOWEVER, FLUE AND CONNECTIONS MUST BE COVERERD UNDER THE PROJECT WARRANTY.

1693 Rimpau Avenue • Corona, California 92881-3202 • State License No. 375584
Phone: (951) 278-5560 • Fax (951) 278-5570 • Website: couts.com